

Energy Auditing and Management: A Case Study to Improve Energy Efficiency and Setting Benchmarking

Pawan Kumar¹, Rahul K. Rajvanshi², Rishabh Sharma³, Preeti Yadav⁴, Prateek Chaturvedi⁵

¹⁻⁵Department of Electrical and Electronics Engineering,
Galgotias College of Engineering & Technology, Greater Noida, UP, India

Email: pawanror@gmail.com, rahulgct2103@gmail.com, bhardwajrishabh@indiatimes.com,
preetyadav2909@gmail.com, prateek19989@gmail.com

Abstract— The paper presents a detailed study of energy auditing of the building to improve its overall energy efficiency. Recorded data of energy consumption of each floor in a building are used to diagnose the weak points of the building energy-usage system and then a detailed energy audit study is carried out. The energy audit of the energy usage focuses mainly on the equipment consumption i.e fans, lighting system, air conditioning system, water pumping system and electronic equipment etc. Based on energy audit results on the total energy consumption of the building for particular time duration the location of equipment and their ratings are the two leading factors for the change of the total energy consumption. Also, for the different time slot the total energy consumption of the equipment varies significantly in summer and winter as well. Therefore, in this paper a comparative study of power demand, equipment cost and their size as well as make has been demonstrated for a sample building.

Keywords— Energy Auditing, Energy Conservation, Power Demand, Recommended Standards, Benchmarking.

I. INTRODUCTION

Building owners in India are facing significant challenges with the rising energy cost and decreasing availability and reliability of energy supply. Rising operating budgets are directly attributable to increasing energy costs for lighting, air conditioning and building services. But unlike many other operational costs, energy costs are controllable. Building energy assessment can assist building owners to learn more about their facilities energy use and take steps to effectively manage the energy use for long term savings.

The first step towards reducing energy consumption is becoming familiar with current energy use and learning how to make existing process more energy efficient. By undertaking an energy assessment/audit, a building owner can identify energy intensive systems and greatest potential for energy savings. All levels of building energy assessment provide the owner with a baseline of their facilities to set performance targets i.e. benchmarking and determine future course of action.

To institutionalize energy efficiency in the country, the Government of India enacted the Energy Conservation Act in 2001. Under the EC Act 2001, the government of India established Bureau of Energy Efficiency (BEE) in March 2002, a statutory authority under the Ministry of Power (MOP)

to enact energy efficiency policies through various regulatory and promotional measures. BEE developed energy efficiency plans which focus on various thrust areas including Energy Efficiency in Commercial Buildings, Energy Conservation Building Code and conduction of Energy Auditors cum Energy Managers certification Program.

BEE launched its first energy efficiency program for existing buildings in 2002. Sample studies conducted in a few selected government buildings in Delhi under the program, have identified energy savings potential of about 30% on average. In the on-going next phase, 17 more buildings in Delhi have been audited. Similar initiatives are being considered for public and private buildings in the state by the authorities as well as the building owners [1]. In the past energy auditing had completed at IIT Bombay campus in 2008. The IIT Bombay electricity bill for the year 2007 was Rs. 10.2 crores. Through energy auditing they save around Rs. 1.75-crores i.e. 17% of the electricity bill in 2007[2].

II. ENERGY AUDIT: A CASE STUDY

The energy audit of a building is a study of building to determine how and where energy is used and to identify methods for energy savings [2]. The primary objective of Energy Audit is to determine ways to reduce energy consumption per unit of product output or to lower operating costs. Energy Audit provides a “bench-mark” i.e. reference point for managing energy in the organization and also provides the basis for planning a more effective use of energy throughout the organization.

Energy Audit can be classified into following two types

- i) Preliminary Audit
- ii) Detailed Audit

Preliminary Audit is quick exercise to:

- Establish energy consumption in the building.
- Estimate the scope for saving.
- Identify the most likely (and the easiest areas of attention).
- Identify immediate improvements/savings.
- Set a ‘reference point’
- Identify areas for more detailed study
- Preliminary energy audit uses existing, or easily obtained data.

A comprehensive audit provides a detailed energy project implementation plan for a facility, since it evaluates all major energy using systems. This type of audit offers the most accurate estimate of energy saving and cost. Detailed energy auditing is carried out in three phases as described in [3]:

Phase I -Pre Audit Phase

Phase II -Audit Phase

Phase III -Post Audit Phase

For the studied case, the next section described the energy requirements of the building having five floors. The data is then collected about ratings and locations of equipments such as fans, lights, air conditioning, computers etc. The collected data is arranged floor-wise and the percentage loading of different loads is considered for a particular time period.

III. ENERGY REQUIREMENTS OF SAMPLE CASE

A building under case study is having four floors and equipped with all the necessary requirements. Tables-I shows floor-wise distribution of peak power consumption of various loads.

TABLE I
FANS LOAD

Fl o or	Name of the company									
	CG	B	P	U	S K	M M	E W	K W	H W	LC
G	32	2	12	15	0	0	0	0	2	5055
I	47	4	8	0	0	0	1	0	0	4695
II	50	10	7	0	2	0	1	0	0	5485
III	57	8	3	1	7	2	0	0	0	6105
IV	0	0	0	0	0	0	0	20	0	1000
T	186	24	30	16	9	2	2	20	2	22340

TABLE II
LIGHT LOAD

Fl o or	Fluorescent Tube				CFL		Bulb		T L	
	P	O	S	B	H	C	P	S	W	LC
G	6	10	7	1	45	5	1	7	9	3995
I	9	2	13	0	17	0	0	1	28	5150
II	17	2	7	0	20	5	0	10	8	3635
III	19	2	4	0	9	5	13	11	4	3290
IV	18	0	0	0	0	0	0	0	0	990
T	69	16	31	1	93	15	4	39	49	17060

TABLE III
COMPUTERS LOAD

Fl o or	Desktop							CPU			
	CP	H P	S M R	S M T	H C L	V N T	HP	P3	P4	LC	
G	36	14	2	2	2	1	36	5	16	4665	
I	66	5	0	3	0	0	66	0	8	4210	
II	12	31	1	1	0	0	12	1	32	5205	
III	2	0	7	1	0	0	2	7	1	1285	
IV	0	0	0	1	0	0	0	0	1	180	
T	116	50	10	8	2	1	116	13	58	15545	

TABLE IV
AIR CONDITIONING SYSTEMS LOAD

Fl o or	Window AC					Split AC		
	VV+	S	A	OID	DK	LG	LC	
G	2	0	0	0	1	1	1	7964
I	2	0	0	1	0	0	0	6000
II	0	0	1	1	0	0	0	4000
III	0	1	0	0	0	0	0	1950
IV	0	0	0	0	0	0	0	0
T	4	1	1	2	1	1	1	19914

TABLE V
WATER PUMP, WATER COOLER,
R.O. SYSTEM AND REFRIGERATOR LOAD

Fl o or	Water Pump		Water Cooler		RO System		Refrigerator		
	KKDS 338+	Kirl- oskar	Voy- ager	Whirlpool Shakti	LC				
G	0	1	1	1	1				1750
I	0	0	0	0	0				0
II	0	1	0	0	0				1600
III	0	0	0	0	0				0
IV	4	0	0	0	0				14800
T	4	2	1	1	1				18150

TABLE VI
FLOOR-WISE DISTRIBUTION AND POWER
CONSUMPTION OF PRINTERS, XEROX MACHINES AND UPS

Fl o or	Printer		Photocopy	UPS	
	HPL	HPD	R	Alpha -1000	LC
G	9	2	1	0	3980
I	0	0	0	0	0
II	1	0	0	0	315
III	0	0	0	1	1200
IV	0	0	0	0	0
T	10	2	1	1	5495

Table [I-VI] shows the number of power equipments, power rating and total power consumption floor-wise. From the data collected it can be noticed that the power consumption for each equipment or devices is not same for different makes. Further the lighting load, fans and the air conditioning system is not uniform at each floor, and hence the huge scope for reduction of power consumption is there at number of floors. The peak power consumption of various loads floor-wise is given below:

Ground Floor	= 27049W
First Floor	= 20055W
Second Floor	= 20240W
Third Floor	= 13830W
Top Floor	= 18590W

Total Energy Consumption = 99764W

The loads were segregated based on the end usage as fans, air conditioning system, lighting, computers and other loads. Quantification, types and necessary measurements were carried out and the details are given as shown in Fig. 1. It can be noticed that the total fans load is 22.4%, computer power load is 15.6%, lighting load is 17.1%, air-conditioning load is 20% and the other like water pump, water coolers etc. is 23.6% of the total connected load requirement. Though, the operating load is not always equal to the connected load. This is because the some loads are required to be operated in morning or in evening hours only like water pump etc. The power load mostly in operation during working hours comprises of more than 75% of the total consumption and this can be easily released from the pie chart.

The sample building is divided in five sections floor-wise like ground floor (G), First Floor (I) etc. The floor-wise section consists of number of room of different size having unique power demands. Therefore, a sample room of dense energy intensity is selected for further energy evaluation to show the effective results. Further, the quantification of the

power consuming devices will help in finding the most sensible area for improving energy efficiency.




Fig.1. Power Consumption in Different Loads

IV. TEST RESULT AND DISCUSSIONS

A. Energy Evaluation of sample room

The relevant data about location, rating and number of equipment in the room have been collected and tabulated as shown below in Table-VII.

TABLE VII
POWER EQUIPMENTS IN SAMPLE ROOM WITH RATING

S. No.	Item/ Make	Qty	Power Rating	LC
1	Fans Usha Havells	11 2	85 50	935 100
2	Lighting CFL Halonix Fluorescent Light	7	20	140
	Small Large	60 2+1	20 55+ 65	1200 175
3	Printers HP Laser	5	315	1575
4	Monitor Compaq Samtron HP Samtel HCL Vintror	14 2 5 2 2 1	30 95 50 90 95 95	420 190 250 180 190 95
5	CPU HPDX2009 P3 P4	14 5 7	15 50 90	210 250 630
Total Loading Capacity				6540

Fig. 2 shows the exact location of the each power consuming equipment and devices in the sample room taken in to consideration. The floor area of the sample room is 13.3m X 8.6m. The total peak load power or the connected load is 6600W. Further the operating hours of each device

varies in a day or in a month or in a season or a year. The number of days is selected unanimously, and summing the

summer and winter day gives the total number of days in a year as shown in Table-VIII independently for each devices.




Fig. 2. Layout of a Sample Room with Actually Connected Load

TABLE VIII
OPERATING HOURS AND DAYS OF POWER EQUIPMENTS

Equipment	Operating hours/day	Operating days in summer	Operating days in winter
Fans	8	140	0
Computer	8	140	75
Lighting	8	35	50
Printer	1	140	75

Actual power consumption of the sample room in a year considering the operating hours per day and number of days in a year, as shown in Table-VIII, can be calculated, and is the following:

- 1) Fan = 1159.2KWh
- 2) Lighting = 1030.2KWh

Total power consumption = 8257.4KWh

B. Recommendation of energy requirement for sample room

As per BEE standards [4] the optimal location, rating and number of equipment without losing any functionality and affecting the environment has been selected as tabulated below in Table-IX. The consumption is described based upon

- 3) Printer = 338.6KWh
- 4) Computer = 4153.8KWh

TABLE IX
FLOOR-WISE DISTRIBUTION AND POWER

S No.	Equipment	No. of equipment	Name of product	Rating	LC
1	Ceiling Fan	6	Havells Fusion 50	50	300
2	Wall Fan	4	Havells	40	160
3	Fluorescent Light	15	Philips	50	750
4	CFL	4	Halonix	20	80
5	Monitor	26	Viewsonic VA1931wa	12	312
6	CPU	26	HP DX2009	15	390
7	Printer	5	HP	315	1575
Total Capacity					3567

the per unit size of floor area in square meters/feet etc. These standards may vary with preference given to specific room. Recommended power consumption of the sample room in a year:

- 1) Fan = 515.2KWh
- 2) Lighting = 564.4KWh

3) Printer = 338.6KWh
 4) Computer = 1207.4KWh
 Total power consumption = 2625.6KWh

Total saving of power consumption of sample room in a year
 = 5631.8KWh




Fig. 3. Layout of a Sample Room with Recommended Power Loads

The sample building selected for energy auditing has 44 rooms including classroom, faculty room, laboratories, offices etc. The total power consumption of the sample building based upon the data collected described above with actual and recommended is described as under:

C. Actual power consumption of whole building in a year:

- 1) Fan = 25020.8KWh
- 2) Computer = 26737.4KWh
- 3) Lighting = 18340KWh
- 4) Air Conditioning system = 22303.6KWh
- 5) Water pump = 6364KWh
- 6) Water cooler = 4340KWh
- 7) Printer and Xerox = 7387.4KWh
- 8) UPS = 2064KWh
- 9) RO system = 215KWh
- 10) Fridge = 1080KWh

Total power consumption in a year = 113852.2KWh
 = 113852 unit

For cost of one unit of Rs. 4/-, the annual electricity bill would be of Rs. 455408/-

D. Recommended power consumption of whole building in a year:

- 1) Fan = 9083.2 KWh
- 2) Computer

All TFT	= 14396.5KWh
All LED	= 8637.8KWh
3) Lighting	
Fluorescent light	= 10730KWh
LED	= 5019.3KWh
4) Air Conditioning system	
All window AC	= 17360KWh
All split AC	= 11760KWh
5) Water pump	= 4945KWh
6) Water cooler	= 2380KWh
7) Printer and Xerox	= 908.3 KWh
8) UPS	= 2064KWh
9) RO system	= 215KWh
10) Fridge	= 302.4KWh

TABLE X
 RECOMMENDATION-I
 TFT, FLUORESCENT LIGHT AND WINDOW AC

Total power consumption in a year	61476 KWh
Annual electricity bill	Rs.245904/-
Total power saving in a year	113852KWh - 61476 KWh = 52376 KWh
Total saving in annual electricity bill	Rs. 209504/-

Implementation of all the above measures recommended as shown in Table-X can bring about a total saving of around Rs.2.1 lakh i.e. 46 % of total present electricity bill. The total investment required would be to the extent of Rs.6.5 lakh with an average simple payback period of around 3 years.

TABLE XI
RECOMMENDATION-II
LED MONITOR, LED LIGHT AND SPLIT AC

Total power consumption in a year	45315 KWh
Annual electricity bill	Rs.181260/-
Total power saving in a year	113852KWh - 45315KWh = 68537KWh
Total saving in annual electricity bill	Rs. 274148/-

Further, the implementation of all the above measures recommended as shown in Table-XI can bring about a total saving of around Rs.2.74 lakh i.e. 60 % of total present electricity bill. The total investment required would be to the extent of Rs.60 lakh with an average simple payback period of around 22 years. This is because of the high investment cost of the LED operating devices. Therefore for small period the first recommendations are preferred.

V. CONCLUSIONS

This paper presented the energy auditing for a sample case having five floors and it can be observed from the results that through energy audit there is a lot of scope of energy savings in building. The significance of energy saving is that if we save one unit at consumer end then we can save two electrical unit and six mechanical equivalent at the generating station. Therefore, all the measures mentioned above are required to be taken in true spirit for achieving sustainable results in the field of energy conservation to improve energy efficiency. The objective of energy audit is to set benchmark, as a feasibility study leading to implementation of an energy management programme. This paper considered only the effect of fans, lighting system, Desktop/PCs and AC system on the final energy consumption and operating efficiency of these equipments can be considered in further studies.

NOMENCLATURE AND POWER RATINGS OF EACH UNIT

A. Table-I

B	- BAJAJ	(80W)
CG	- Crompton Greaves	(75W)
EW	- East West	(90W)
HW	- Havells (Wall Fan)	(40W)
KW	- Khaitan (Wall Fan)	(50W)
MMI	-	(95W)
P	- Polar	(95W)
SK	- SummerKing	(90W)

U	- Usha	(85W)
LC	- Load Capacity in watts	
T	- Total	

B. Table-II

CP	- Compaq TFT	(30W)
HP	- CRT	(50W)
SMR	- Samtron CRT	(95W)
SMT	- Samtel CRT	(90W)
HCL	- CRT	(95W)
VNT	- Vintron CRT	(95W)
HP DX	-	(15W)
P3	-	(50W)
P4	-	(90W)
LC	- Load Capacity in watts	
T	- Total	

C. Table-III

P	- Philips	(55W)
O	- Osram	(65W)
S	- Surya	(65W)
B	- Bajaj	(20W)
H	- Havells	(15W)
C	- Crompton	(60W)
W	- Wipro	(100W)
TL	- Tube Light	

D. Table-IV

VV+	- Voltas Vertis Plus	(2000W)
S	- Samsung	(1950W)
A	- Amtrek	(2000W)
OID	- OptimalD	(2000W)
DK	- Durakool	(1889W)
LG		(2075W)

E. Table-V

Kirloskar KDS338+	(3700W)
Kirloskar	(1550W)
Voyager	(50W)
Whirlpool Shakti	(150W)

F. Table-VI

HPL	- HP Laserjet	(315W)
HPD	- HP Deskjet	(350W)
R	- Reckon	(445W)
Alpha-1000		(1200W)

REFERENCES

- [1] USAID ECO-III Project, *Energy assessment guide for commercial buildings*, International resources group Hauz-Khas, New Delhi, India.
- [2] Chikku Abraham, Mel George, Victore Jose, Sharath Deshpande, *Energy audit of IIT Mumbai campus*, Dept. of Energy Science and Engineering, IIT Bombay, India 2007
- [3] Bureau of energy efficiency, *Energy management and audit guide*, RK Puram, New Delhi, 2009. Available online at <http://www.bee-india.nic.in/>

[4] Bureau of energy efficiency, USAID ECO-II Project, *Energy conservation building code* RK Puram New Delhi India, 2009 [Online]. Available: <http://www.bee-india.nic.in/>

Pawan Kumar is Assistant Professor in the Department of Electrical & Electronics Engineering, Galgotias College of Engineering & Technology, Greater Noida, U.P., India. He graduated from Kurukshetra University and received his M.Tech. degree from Indian Institute of Technology, Delhi. He is currently a PhD scholar at Jamia Millia Islamia, New Delhi. He is also a certified Energy Manager cum Auditor by BEE, Ministry of Power, Govt. of India.

Rahul K Rajvanshi, Rishabh Sharma, Preeti Yadav and Prateek Chaturvedi- are the B.Tech. 4th year students in the department of Electrical & Electronics Engineering, Galgotias College of Engineering & Technology, Greater Noida, U.P., India. They are about to submit their dissertation part-II (Major Project) for the partial fulfilment of Degree of Bachelor of Technology.